

**NOTES:**


The water meter must be inside the building if a building exists.

Seasonal water services must be drained prior to November 1 of each year and is the responsibility of the customer.

The water service pipe shall be Type K copper, annealed, seamless ASTM B88 from the main to the meter setting.

All components downstream of first curb stop must be installed outside of R.O.W. and per the Holland BPW standards. All components downstream of the meter are the responsibility of the irrigation contractor.

At no time is this detail to supercede but rather to work in conjunction with other standards and specifications.

	<p align="center"><b>CITY OF HOLLAND, MICHIGAN</b>          Holland Board of Public Works          Utility Services Department          625 Hastings Ave., Holland, MI 49423          Phone: (616) 355-1643 - Fax: (616) 355-1560          Director: John Van Uffelen, P.E.</p>	<p><b>SEASONAL IRRIGATION METER          STANDARD DETAIL</b></p>						
		<table border="1"> <tr> <td>DRAWN BY JAB</td> <td>SCALE NONE</td> <td>DATE 06-16-2008</td> </tr> <tr> <td>APPROVED BY DJS</td> <td>SHEET WS-4</td> <td>DWG FILE Seasonal Irrigation.dwg</td> </tr> </table>	DRAWN BY JAB	SCALE NONE	DATE 06-16-2008	APPROVED BY DJS	SHEET WS-4	DWG FILE Seasonal Irrigation.dwg
DRAWN BY JAB	SCALE NONE	DATE 06-16-2008						
APPROVED BY DJS	SHEET WS-4	DWG FILE Seasonal Irrigation.dwg						